



ITS TESTING LABORATORY PRIVATE LIMITED

Laboratory: A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar - 201305, (U.P.)

(An ISO 9001: 2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory)

Website: www.itslab.in, Email: itrlclab@gmail.com, info@itslab.in, contact@itslab.in

+91 9911659800, 9305780312, 09958849764



TC-11181

Doc. No. – ITS/7.8-01, Page No. – 1 of 1

TEST REPORT

Water Sample Analysis

Report Code-W-220425-51

Issue Date 24/04/2025

Issued To : M/S ST XAVIER'S PUBLIC SCHOOL
RAMPUR, JAHANGANJ, AZAMGARH, 276131

Sample Description : Drinking Water Sample
Source of Water : RO Water
Sample Drawn On : 21/04/2025
Sample Drawn By : Mr. Pankaj (ITS LAB Representative)
Sampling Plan & Procedure : IS:17614 (Part-1):2021
Sample Quantity : 2.0 Liter in Pet Bottle & 200 ml Glass Sterilized Bottle
Weather Condition : Clear
Sample Received On : 22/04/2025
Analysis Duration : 22/04/2025 To 24/04/2025
Test Specification To Be Used : IS:10500:2012

ANALYSIS TEST RESULTS

Chemical Analysis

S. No.	Parameter	Test Method	Results	Requirement (Acceptable Limit)	Permissible Limit in absence of alternate source
1.	pH Value @ 25°C	IS:3025(Part-11)	6.78	6.5 – 8.5	-
2.	Colour (Hazen)	IS:3025(Part-04)	<5.0	5	15
3.	Odour	IS:3025(Part-05)	Agreeable	Agreeable	Agreeable
4.	Taste	IS:3025(Part-7 & 8)	Agreeable	Agreeable	Agreeable
5.	Turbidity (NTU)	IS:3025(Part-10)	<1.0	1	5
6.	Total Hardness (as CaCO ₃) (mg/l)	IS:3025(Part-21)	22.0	200	600
7.	Chloride(as Cl) (mg/l)	IS:3025(Part-32)	32.0	250	1000
8.	Calcium (as Ca) (mg/l)	IS:3025(Part-40)	3.2	75	200
9.	Total Iron (as Fe) (mg/l)	IS:3025(Part-53)	<0.05	1.0	-
10.	Nitrate (as NO ₃)	IS:3025(Part-34)	<1.0	45	No Relaxation
11.	Total Dissolved Solids (TDS) (mg/l)	IS:3025(Part-16)	85	500	2000
12.	Alkalinity (as CaCO ₃) (mg/l)	IS:3025(Part-23)	31.0	200	600
13.	Fluoride (as F) (mg/l)	IS:3025(Part-60)	<0.1	1.0	1.5
14.	Sulphate (as SO ₄) (mg/l)	IS:3025(Part-24)	<1.0	200	400
15.	Magnesium (as Mg) (mg/l)	IS:3025(Part-46)	3.42	30	100

Microbiological Analysis

RESULTS

S. No.	Parameter	Test Method	Results	Required as per IS-10500:2012
1.	Escherichia coli	IS-15185:2016	Absent	Absent/100ml
2.	Coliform Bacteria	IS-15185:2016	Absent	Absent/100ml

Remarks: Based on above tested parameter, Water sample meets as per IS-10500:2012 in specification.

Note: - Report shall not be produce except in full without approval of the laboratory.

Reviewed by
Babita Darwal
(Microbiologist)



End of Report



Terms & Conditions :

1. Test reports are valid only for the samples tested in our laboratory. 2. Samples will destroyed as per quality policy.
3. Any complaints about the report should be communicated in writing within 7 days.
4. Total liability of our laboratory is limited to invoiced amount.

Principal

St. Xavier's Public School
Rampur, Jahanaganj, Azamgarh

Manager

St. Xavier's Public School
Rampur Jahanaganj, Azamgarh

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION**CERTIFICATE**No. स.वि. 38/5.38/79/2025Dated: 19-05-2025

It is certified that an inspection team headed by **Vinay Shankar Singh** (Name of Officers with designation) from **A. D. O. (P) Jahanaganj Azamgarh PHED** inspected the **St. Xavier's Public School, Rampur, Jahanaganj, Azamgarh** (Name & Address of the school) on **15.05.2025** (Date of inspection) and on the basis of Water Test Report (Attached) bearing no **Doc. No.-ITS/7.8-01 Report Code- W-220425-51** Dated **24/04/2025** of **ITS TESTING LABORATORY PRIVATE LIMITED A-114, Sector-80, Phase-II Noida, Gautam Budh Nagar-201305, (U.P.) (PHED Lab)** certified that the **St. Xavier's Public School, Rampur, Jahanaganj, Azamgarh** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till **18.05.2026**

Signature with seal :

Name

: **Vinay Shankar Singh**

Designation

: **A. D. O. (P) Jahanaganj
Azamgarh**

Name & Address of the Office/Department

To

**St. Xavier's Public School,
Rampur, Jahanaganj, Azamgarh
(Name & Address of the Institution)**



Principal

**St. Xavier's Public School
Rampur, Jahanaganj, Azamgarh**



Manager

**St. Xavier's Public School
Rampur Jahanaganj, Azamgarh**